

Observation Number:	201810249
Originator:	
Date Created:	18-Jul-2018
Business Unit:	AS EAAA
Business Group:	Operations Services Europe & Africa
Project/Office:	Western Gas Alliance
Sub Business Group:	Transmission & Distribution
Site/Office Name:	Western Gas Alliance 1855005/6
Work Related or Non-Work Related Observation?:	Work Related
Exact Location or Project of Act/Condition/Safe Behaviour:	Newport Stores, Large meeting room.
Observation Type:	Unsafe Condition
Observer Name:	Paul Breakey
Observer Email Address:	chris.wilde@amecfw.com
Stakeholder:	Wood
Observation Date:	07-Mar-2018
Observation Time:	09:45
Observation Close Date:	
Details of safety observation:	Yet again 3 extension leads haven't been PAT tested for electrical safety. 1 of the plugs has a sticker dated 2013
Immediate action taken:	
Supporting Information:	
Feedback required?:	No
Comments from Reviewer	
Cancel Comments:	Not wood related