

Observation Number:	201810267
Originator:	
Date Created:	18-Jul-2018
Business Unit:	AS EAAA
Business Group:	Operations Services Europe & Africa
Project/Office:	Western Gas Alliance
Sub Business Group:	Transmission & Distribution
Site/Office Name:	Western Gas Alliance 1855005/6
Work Related or Non-Work Related Observation?:	Work Related
Exact Location or Project of Act/Condition/Safe Behaviour:	142 Ystrad Deri, Dukestown, Tredegar
Observation Type:	Unsafe Condition
Observer Name:	Richard Date
Observer Email Address:	carl.jones@wwutilities.co.uk
Stakeholder:	Wood
Observation Date:	02-Apr-2018
Observation Time:	14:45
Observation Close Date:	12-Sep-2018
Details of safety observation:	Team were transferring a service they put a test on the service and it was leaking they found that a 25/20 electro fusion reducer this should not have leaked. so the team cut out and renewed the service
Immediate action taken:	The team cut out and renewed the service and gave the fitting to Pete Tyler to return to the depot for investigation to Rod Evans then passed to Tom James
Supporting Information:	
Feedback required?:	No