

Observation Number:	201816987
Originator:	
Date Created:	13-Nov-2018
Business Unit:	AS EAAA
Business Group:	Capital Projects EAAA
Project/Office:	SPIN - CONTRAST MEDIA PLANT EXPANSION
Service Line:	SERC
Site/Office Name:	Spin- CMPE Site
Work Related or Non-Work Related Observation?:	Work Related
Exact Location or Project of Act/Condition/Safe Behaviour:	B7 piano terra 4ta campata
Observation Type:	Unsafe Act
Observer Name:	sergi domenico
Observer Email Address:	domenico.sergi@woodplc.com
Stakeholder:	Client
Observation Date:	12-Nov-2018
Observation Time:	07:45
Observation Close Date:	06-Dec-2018
Observation Category:	Work Environment Traffic routes and parking areas
Details of safety observation:	la canale di HVAC istallata nel progetto al piano terra, risulta essere stata urtata e danneggiata da un muletto il quale gli ha danneggiato la coibentazione .
Immediate action taken:	segnalato. nessuno presente al momento dell'osservazione.
Supporting Information:	
Feedback required?:	No