

| | |
|---|--|
| Observation Number: | 201810249 |
| Originator: | |
| Date Created: | 18-Jul-2018 |
| Business Unit: | AS EAAA |
| Business Group: | Operations Services Europe & Africa |
| Project/Office: | Western Gas Alliance |
| Service Line: | Transmission & Distribution |
| Site/Office Name: | Western Gas Alliance 1855005/6 |
| Work Related or Non-Work Related Observation?: | Work Related |
| Exact Location or Project of Act/Condition/Safe Behaviour: | Newport Stores, Large meeting room. |
| Observation Type: | Unsafe Condition |
| Observer Name: | Paul Breakey |
| Observer Email Address: | chris.wilde@amecfw.com |
| Stakeholder: | Wood |
| Observation Date: | 07-Mar-2018 |
| Observation Time: | 09:45 |
| Observation Close Date: | |
| Details of safety observation: | Yet again 3 extension leads haven't been PAT tested for electrical safety. 1 of the plugs has a sticker dated 2013 |
| Immediate action taken: | |
| Supporting Information: | |
| Feedback required?: | No |
| Comments from Reviewer | |
| Cancel Comments: | Not wood related |