

Originator:	
Date Created:	10-Aug-2016
Business Unit:	AS EAAA
Business Group:	Capital Projects EAAA
Project/Office:	EPC2 Antwerp
Service Line:	SERC
Site/Office Name:	EPC2 Antwerp - Site
Home or Work Related Observation?:	Work
Exact Location or Project of Act/Condition/Safe Behaviour:	J-101 near 2-TF-6 area
Observation Type:	Safe Behaviour
Observer Name:	Cristian Loi
Observer Email Address:	TIOTIE.ExxonmobilAntwerp@fwceu.com
Stakeholder:	Contractor
Observation Date:	09-Aug-2016
Observation Time:	08:30
Observation Close Date:	12-Aug-2016
Name of Individual or Team:	TECHIMP
Details of safety observation:	TECHIMP crew were busy with the relocation of a power socket inside the J-101 in order to proceed with the relocation of an flex station. Since the power socket was under voltage, as per the work permit, before to start the activities it was necessary to perform the LOTO procedure with EM. The procedure was followed correctly and so they started to work in a safe way.
Immediate action taken:	No action but congratulations.
Supporting Information:	
Feedback required?:	No