

Observation Number:	201903441	
Originator:		
Date Created:	28-Feb-2019	
Business Unit:	AS EAAA	
Business Group:	Operations Services MERC	
Project/Office:	PSNS - SEIC TSS	
Service Line:	Russia Caspian	
Site/Office Name:	PSNS Office	
Work Related or Non-Work Related Observation?:	Work Related	
Exact Location or Project of Act/Condition/Safe Behaviour:	Elevator	
Observation Type:	Unsafe Condition	
Observer Name:	LUKMANOVA, Irina	
Observer Email Address:	Irina.Lukmanova@woodplc.com	
Stakeholder:	Wood	
Observation Date:	01-Mar-2019	
Observation Time:	08:45	
Observation Close Date:	01-Mar-2019	
Observation Category:	Work Environment Pedestrian routes (floors, stairs etc.)	
Details of safety observation:	A person was entering into the elevator while closing doors, the sensor didn't have enough time to react and stop doors closing. So the person got quite a strong hit by the door (to the shoulder).	
Immediate action taken:	People inside the elevator agreed that sensor is not such reactive and people should avoid speedy entering without ensuring that the door start opening back. This matter has been reported to building maintenance to reset the lift door closing time. No injuries occurred to personnel involved in this matter	
Supporting Information:		
Feedback required?:	No	
Reasons for Amendment		
Comment	Entered By	Date Entered
Immediate action section information added	Pat Quinn	01-March-2019 05:30