

Observation Number:	201903441
Originator:	
Date Created:	28-Feb-2019
Business Unit:	AS EAAA
Business Group:	Operations Services MERC
Project/Office:	PSNS - SEIC TSS
Service Line:	Russia Caspian
Site/Office Name:	PSNS Office
Home or Work Related Observation?:	Work
Exact Location or Project of Act/Condition/Safe Behaviour:	Elevator
Observation Type:	Unsafe Condition
Observer Name:	LUKMANOVA, Irina
Observer Email Address:	Irina.Lukmanova@woodplc.com
Stakeholder:	Wood
Observation Date:	01-Mar-2019
Observation Time:	08:45
Observation Close Date:	01-Mar-2019
Observation Category:	Work Environment Pedestrian routes (floors, stairs etc.)
Details of safety observation:	A person was entering into the elevator while closing doors, the sensor didn't have enough time to react and stop doors closing. So the person got quite a strong hit by the door (to the shoulder).
Immediate action taken:	People inside the elevator agreed that sensor is not such reactive and people should avoid speedy entering without ensuring that the door start opening back. This matter has been reported to building maintenance to reset the lift door closing time. No injuries occurred to personnel involved in this matter
Supporting Information:	
Feedback required?:	No

Reasons for Amendment		
------------------------------	--	--

Comment	Entered By	Date Entered
Immediate action section information added	Pat Quinn	01-March-2019 05:30