

Observation Number:	201809730
Originator:	
Date Created:	11-Jul-2018
Business Unit:	AS EAAA
Business Group:	Operations Services Europe & Africa
Project/Office:	Western Gas Alliance
Sub Business Group:	Transmission & Distribution
Site/Office Name:	Western Gas Alliance 1855005/6
Work Related or Non-Work Related Observation?:	Work Related
Exact Location or Project of Act/Condition/Safe Behaviour:	Heol Yr Forlan
Observation Type:	Unsafe Condition
Observer Name:	Simon Waite
Observer Email Address:	carl.jones@wwutilities.co.uk
Stakeholder:	Contractor
Observation Date:	01-Feb-2018
Observation Time:	11:45
Observation Close Date:	16-Jul-2018
Details of safety observation:	The team were digging down and found a pot ended electric cable not on the plans, they contacted WPD who came to site and found this was a live cable. This has now been dealt with . They also found another cable on site WPD tested and said there was no reading to suggest a live cable
Immediate action taken:	WPD called to site
Supporting Information:	
Feedback required?:	No