

<b>Observation Number:</b>	201903441
<b>Originator:</b>	
<b>Date Created:</b>	28-Feb-2019
<b>Business Unit:</b>	AS EAAA
<b>Business Group:</b>	Operations Services MERC
<b>Project/Office:</b>	PSNS - SEIC TSS
<b>Service Line:</b>	Russia Caspian
<b>Site/Office Name:</b>	PSNS Office
<b>Home or Work Related Observation?:</b>	Work
<b>Exact Location or Project of Act/Condition/Safe Behaviour:</b>	Elevator
<b>Observation Type:</b>	Unsafe Condition
<b>Observer Name:</b>	LUKMANOVA, Irina
<b>Observer Email Address:</b>	Irina.Lukmanova@woodplc.com
<b>Stakeholder:</b>	Wood
<b>Observation Date:</b>	01-Mar-2019
<b>Observation Time:</b>	08:45
<b>Observation Close Date:</b>	01-Mar-2019
<b>Observation Category:</b>	Work Environment Pedestrian routes (floors, stairs etc.)
<b>Details of safety observation:</b>	A person was entering into the elevator while closing doors, the sensor didn't have enough time to react and stop doors closing. So the person got quite a strong hit by the door (to the shoulder).
<b>Immediate action taken:</b>	People inside the elevator agreed that sensor is not such reactive and people should avoid speedy entering without ensuring that the door start opening back. This matter has been reported to building maintenance to reset the lift door closing time. No injuries occurred to personnel involved in this matter
<b>Supporting Information:</b>	
<b>Feedback required?:</b>	No

<b>Reasons for Amendment</b>		
------------------------------	--	--

<b>Comment</b>	<b>Entered By</b>	<b>Date Entered</b>
Immediate action section information added	Pat Quinn	01-March-2019 05:30